



ST. TAMMANY PARISH

MICHAEL B. COOPER
PARISH PRESIDENT

September 27, 2023

Please find the following addendum to the below mentioned BID.

Addendum No.: 2

Bid#: 23-30-2

Project Name: Safe Haven Entrance Improvements

Bid Due Date: Tuesday, October 3, 2023

QUESTIONS & ANSWERS:

1. Is a certification required for the pervious pavement work? **NO.**
2. Who is responsible for the electrical permit? **THE CONTRACTOR WILL BE RESPONSIBLE FOR APPLYING FOR THE PERMIT AND PAYING ALL FEES.**
3. Can we close the entire driveway for the installation of the new culvert? **IT IS INTENDED THAT THE CULVERT WOULD BE INSTALLED USING THE SAME PHASING THE PAVEMENT WORK PER THE DRAWINGS. HOWEVER, IF THE INSTALLATION CAN BE PERFORMED WITH NO INTERRUPTION TO TRAFFIC AND DONE DURING NON-PEAK TIMES THEN CONSIDERATION WILL BE GIVEN. IT WILL BE THE RESPONSIBILITY OF THE CONTRACTOR TO PROVIDE A DETAILED PLAN FOR THIS WORK THAT WILL BE SUBJECT TO REVIEW AND APPROVAL BY THE ENGINEER AND THE PARISH.**

End of Addendum # 2