

ADDENDUM NO. 3

TO: ALL PLAN HOLDERS

TO: All Plan Holders:

**Lawrence D. Crocker School
2300 General Taylor Street
New Orleans, LA 70115**

**Orleans Parish School Board
ITB 24 – FAC 0027
Architect's Project No. M22-015**

For The: Lawrence D. Crocker Roof Replacement

**Architect: Modus Inc. Architects & Planners
2300 Marengo Street
New Orleans, LA 70115**

Date Issued: October 27, 2023

This addendum modifies the original Solicitation Documents for the Project dated September 13, 2023 (Specifications) and August 10, 2023 (Drawings). The Items in this addendum shall govern the Work, taking precedence over previously issued specifications and drawings governing the items mentioned. Acknowledge receipt of the Addendum in the Space Provided on the Sealed Bid Form.

Item 1 – Sealed bids will be received for the Orleans Parish School Board (OPSB) by the Procurement Department, Room 5055, 2401 Westbend Parkway, New Orleans, Louisiana 70114, until **2:00 PM CST** on the **rescheduled date of Thursday, November 2, 2023.**

Item 2 - All Request for information and correspondents must be received by Modus Inc no later than **Friday, October 27, 2023 at 5:00pm.**

Item 3 – Revisions to Specifications:

- A. Section 070150 Preparation for Re-Roofing. Refer to 3.3.B.1. Refer to 3.4.A.1.
- B. Section 075216 SBS Modified Bituminous Roofing. Refer to 2.4.B. Revise to read as follows: Polyisocyanurate Board Insulation: ASTM C 1289, Type 11, Class 1, Grade 2 or Type 11, Class 1, Grade 3, felt or glass-fiber mat facer on both major surfaces. R-Value of 25. Flat insulation panels in manufacturer's standard thicknesses.
- C. The mechanical fastening method for the insulation and coverboard must meet the performance requirements for the project.
- D. Other manufacturers that meet the performance requirements may be used.

Item 4 – Revisions to Drawings - NONE

END OF ADDENDUM NO. 3